

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 290

Dated: 21/10/2024

It is certified that an inspection team headed by Mr. Akhil Bajpai Sub Eng./Lab Incharge

(Name of Officers with designation) from Smt. Anita Jayant chemist

(Name of Department/ Office) inspected the Public Health Engineering department Gwalior

(Name &amp; Address of the school) on 21/10/2024 (date of inspection) and found that the DOON PUBLIC SCHOOL Gwalior (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building &amp; the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year [21/10/2024 to 20/10/2025]

Signature with Seal: **Lab Incharge**  
**Distrect Water Testing Laboratory**  
**A.P.H.E. Division, Gwalior (M P)**  
 Name: Mr. Akhil Bajpai  
 Designation: Sub Engineer / Lab Incharge  
 Name & Address of the Office / Department: P.H.E.D Gwalior

To

Principal  
 Doon public school  
 Shivpuri Link Road Gwalior  
 (Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Public Health Engineering Department District Water- Testing  
Laboratory Gwalior**

**Test Report**

Type of sample: Water Sample ✓  
Particular of sender:- Principal Doon Public School Shivpuri Link Road , Gwalior (M.P.)

Sample No.	Place of Collection and Details of Sample	Date of collection
1	Drinking Water	18.10.2024
2	-	-
3	-	-
4	-	-

Particular of Sample :  
Date of Receipt: 18.10.2024  
Lab Reference No: \_\_\_\_\_ Time of Receipt: 12:40 PM  
Date of Analysis: 21.10.2024

**Nature of Study – Chemical and Bacteriological Analysis**

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
<b>PHYSICAL TESTE</b>								
1	Turbidity	NTU	1.0	5.0	1.0	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
<b>CHEMICAL TESTE</b>								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	6.5	-	-	-
6	Alkalinity	Mg/L	200	600	36	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	32	-	-	-
8	Nitrate as No3	Mg/L	45	45	04	-	-	-
9	Total hardness	Mg/L	200	600	88	-	-	-
10	Calcium as Ca	Mg/L	75	200	16	-	-	-
11	Magnesium as mg	Mg/L	30	100	11	-	-	-
12	Iron	Mg/L	0.3	1.0	0.12	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	156	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.10	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	06	-	-	-
<b>BECT. FEACAL TESTE</b>								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under " Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst  
District Water Testing Lab  
P.H.E Division Gwalior

Lab Incharge  
District Water Testing Laboratory (M.P.)  
P.H.E. Division, Gwalior (M P)

No. 290 /PHED/ Date :- 21/10/2024